

Annual Drinking Water Quality Report - 2025

GA2310003

WILLIAMSON

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

WILLIAMSON is Purchased Surface Water

For more information regarding this report contact:

Name: Pamela Schoentag

Phone: 770-227-8380

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead

exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

SWA = Source Water Assessment

Source Water Name

GRIFFIN WATER SYSTEM

Type of Water

SW

Report Status

Active

Location

Master Meter @ city limits

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	08/01/2024	1.3	1.3	0.0555	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Water Quality Test Results

- Definitions: The following tables contain scientific terms and measures, some of which may require explanation.
- Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.
- Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- na: not applicable.
- mrem: millirems per year (a measure of radiation absorbed by the body)
- ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
- ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Water Quality Test Results

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2025	41	31 - 42.9	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	47	28.8 - 55.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

**2025 CCR Supplemental Lead and Copper CCR Information
For (GA2310003) Water System**

Required Lead Language: *Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Williamson Water System is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Scott Huckaby, 770-227-8380. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.*

Analyte	Date Sampled	MCLG	Action Level (AL)	Range		Units	Violation
				Low	High		
Lead	7/30/24	0	15	0	0	ppb	NO
Copper	7/30/24	1.3	1.3	0	0.055	ppm	NO

Lead and Copper Range Data.

To access all individual Lead Tap Sample results for Williamson Water System, contact Pamela Schoentag at 770-227-8380.

To access all individual Lead Tap Sample

The Service Line Inventory (SLI) is a requirement under the Lead and Copper Rule Revisions (LCRR) to help water systems identify and replace lead service lines. It mandates that all public water systems develop and maintain an inventory of service line materials to assess the presence of lead and protect public health. The inventory will support proactive lead reduction efforts and ensure compliance with regulatory requirements to minimize lead exposure in drinking water.

To access the SLI for Williamson Water System, go to <https://ga-epd.120water-ptd.com>

MICROBIOLOGICAL CONTAMINANTS

Contaminant and Unit of Measurement	Year	MCL Violation (Yes/No)	Amount Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Total Organic Carbon (ppm)	2025	No	2.00	1.60-2.38	NA	TT	Naturally present in the environment
Contaminant and Unit of Measurement	Year	MCL Violation (Yes/No)	Level Detected	The Lowest Monthly Percentage of Samples Meeting Regulatory Limits	MCLG	MCL	Likely Source of Contamination
Turbidity (NTU)	2025	No	0.26	97%	NA	TT	Soil runoff

INORGANIC CONTAMINANTS

Contaminant and Unit of Measurement	Year	MCL Violation (Yes/No)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Fluoride (ppm)	2025	No	0.74	ND-1.12	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate + Nitrite (ppm)	2025	No	0.15	ND-0.30	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

STAGE 1 DISINFECTANTS AND DISINFECTION BY-PRODUCTS

Contaminant and Unit of Measurement	Year	MCL Violation (Yes/No)	Level Detected	Range of Results	MRDLG	MRDL	Likely Source of Contamination
Chlorine (Free) (ppm)	2025	No	1.59	0.63-2.06	4	4	Water additive used to control microbes
Chlorine Dioxide (ppb)	2025	No	195	ND-720	800	800	Water additive used to control microbes
Chlorite (ppm)	2025	No	0.53	ND-0.76	0.8	1	By-product of drinking water disinfection

STAGE 2 DISINFECTANTS AND DISINFECTION BY-PRODUCTS

Contaminant and Unit of Measurement	Year	MCL Violation (Yes/No)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
HAA5 [Haloacetic Acids] (ppb)	2025	No	47.43	16.40-70.30	NA	60	By-product of drinking water disinfection
TTHM [total trihalomethanes] (ppb)	2025	No	61.10	17.34-70.40	NA	80	By-product of drinking water disinfection

LEAD AND COPPER (Tap water samples were collected from sites throughout the community)

Contaminant and Unit of Measurement	Year	AL Exceedance (Yes/No)	90th Percentile Result	Range Low-High	No. of Sampling Sites Exceeding the AL / Total Sites	MCLG	AL (Action Level)	Likely Source of Contamination
Lead (ppb)	2025	No	1.33	ND-4.00	0/30	0	15	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Copper (ppm)	2025	No	0.12	ND-0.39	0/30	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

UNREGULATED CONTAMINANTS

Contaminant and Unit of Measurement	Year	MCL Violation (Yes/No)	Level Detected	Range of Results	SMCLG	SMCL	Likely Source of Contamination
Aluminum (ppm)	2025	No	1.1	NA	NA	0.05-0.2	Erosion of natural deposits; residual from water treatment process

UNREGULATED CONTAMINANTS

Contaminant and Unit of Measurement	Year	Average Result	Range of Results	Likely Source of Contamination
Iron (ppb)	2025	25.13	16.94-30.83	Naturally occurring
Manganese (ppb)	2025	12.53	8.23-18.39	Naturally occurring
pH (units)	2025	7.32	7.17-7.47	Naturally occurring